

GWXT.R40938 - Auxiliary Locks

Auxiliary Locks

IPIXA SECURITY LTD

128 City Rd

London, EC1V 2NX United Kingdom

R40938

Auxiliary locks of the electromagnetic type Model(s) AEL0221.UL, AEL0222.UL, AEL0241.UL, AEL0242.UL

Last Updated on 2022-12-06

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2022 UL LLC."

GWXT.GuidelInfo - Auxiliary Locks

[Fire Doors] (Hardware) (Builders' Hardware) Auxiliary Locks

[See General Information for Builders' Hardware](#)

USE AND INSTALLATION

This category covers auxiliary locks for use on swinging fire doors having a rating up to and including 3 h unless a reduced rating is otherwise indicated in the individual certifications.

Auxiliary locks are intended for installation on certified fire door frames and/or certified swinging fire doors in accordance with the installation instructions packaged with the device. The auxiliary locks are intended to be used on fire doors and/or frames in addition to the primary latching device required for use on fire doors and/or frames.

Authorities Having Jurisdiction should be consulted before installing auxiliary locks on fire doors and/or frames.

PRODUCT IDENTITY

One of the following product identities appears on the product:

Auxiliary Lock

Auxiliary Lock Subassembly

ADDITIONAL INFORMATION

For additional information, see Builders' Hardware ([GWTZ](#)), Hardware ([GWGR](#)), Fire Doors ([GSNV](#)) and Fire-resistance Ratings ([BXRH](#)).

REQUIREMENTS

The basic standard used to investigate products in this category is [ANSI/UL 10B](#), "Fire Tests of Door Assemblies."

Where indicated in the individual certifications, products have additionally been investigated to [ANSI/UL 10C](#), "Positive Pressure Fire Tests of Door Assemblies."

UL MARK

The Certification Mark of UL on the product is the only method provided by UL to identify products manufactured under its Certification and Follow-Up Service. The [Certification Mark](#) for these products includes the UL symbol, the words "CERTIFIED" and "SAFETY," the geographic identifier(s), and a file number.

Additional Certification Markings

Products may be marked with any qualifications to the product hourly rating.

The UL symbol, the letter "F" (for those products investigated to [ANSI/UL 10B](#)) and the letter "f" (for those products investigated to [ANSI/UL 10C](#)) and any qualifications to the product hourly rating are cast or stamped on the exposed surface if the entire Certification Mark is not visible after installation of the product.

Products additionally investigated to [ANSI/UL 10C](#) may be so noted on the product.

Alternate UL Mark

The Listing Mark of UL on the product is the only method provided by UL to identify products manufactured under its Listing and Follow-Up Service. The Listing Mark for these products includes the UL symbol (as illustrated in the Introduction of this Directory) together with the word "LISTED," a control number, and the product name "Auxiliary Lock" or "Auxiliary Lock Subassembly," and any qualifications to the product hourly rating. In addition, the UL symbol and the letter "F" (for those products investigated to ANSI/UL 10B) and the letter "f" (for those products investigated to ANSI/UL 10C) and any qualifications to the product hourly rating are cast or stamped on the exposed surface if the whole Listing Mark is not visible after installation of the product.

Products additionally investigated to ANSI/UL 10C may be so noted on the UL Listing Mark.

* * * * *

UL, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. UL shall not incur any obligation or liability for any loss, expense or damages, including incidental or consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Guide Information.

Last Updated on 2013-05-16

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2022 UL LLC."